



Project: Angle Design	Contract: 1472-2
Subject: DESIGN D – 2400x1200mm	Sheet No. 0
Date: 19/10/2021	By: A.N

Concorde Glass Ltd.,
Linx House,
104 Waterloo Rd,
Mablethorpe,
LN12 1LE,
UK.

Angle Design
1472-2
DESIGN C – 2400x1200mm
8mm Angle

Analysis By	Checked By
A.N	T.S.

2	08/12/2021	T.S	Amended
1	06/12/2021	T.S	Amended
0	19/10/2021	T.S.	Issued
Revision	Date	Issued By	Comment



Project: Angle Design	Contract: 1472-2
Subject: DESIGN D – 2400x1200mm	Sheet No. 1
Date: 19/10/2021	By: A.N

Contents

Actions/Result Summary:	2
Introduction:.....	2
Actions:.....	2
Assumption:.....	2
Result Summary:.....	2
Sketch of System:	3
Loading:	4
Capacity of 75x50x8mm Angle:	4
Capacity of angle Based on 2400mm×1200mm Glass floor – (worst case):	4
Check 1 – 2400mm Long leg:	4
Check 2 – 1200mm Long leg:	5



Project: Angle Design	Contract: 1472-2
Subject: DESIGN D – 2400x1200mm	Sheet No. 2
Date: 19/10/2021	By: A.N

Actions/Result Summary:

Introduction:

T. Singleton & Associates Consulting Engineers (TSA) have been commissioned by Concorde Glass Ltd to carry out an Angle Design to support 2400×1200 Glass Floor.

Actions:

Load = 4kN/m²

(As per client instruction)

Assumption:

Steel Grade S355

Result Summary:

Angle: 75x50x8mm Grade S355 Mild Steel Angle.

Weld: Full penetration Butt weld at four corners.

Note: To be fabricated in accordance with BS EN 1090 Execution Class 2

Project: Angle Design	Contract: 1472-2
Subject: DESIGN D – 2400x1200mm	Sheet No. 3
Date: 19/10/2021	By: A.N

Sketch of System:




FIGURE 1 SHOWS AN ELEVATION VIEW




FIGURE 2 SHOWS THE PATTERN OF THE LOAD DISTRIBUTED ON THE GLASS FLOOR

Project: Angle Design	Contract: 1472-2
Subject: DESIGN D – 2400x1200mm	Sheet No. 4
Date: 19/10/2021	By: A.N

Loading:

Live load = 4kN/m^2 (SLS)

Dead load (Self weight of glass) = $0.033\text{m} \times 25\text{kN/m}^3 = 0.825\text{kN/m}^2$ (SLS)

Total load = $(4\text{kN/m}^2 \times 1.5) + (0.825\text{kN/m}^2 \times 1.35) = 7.11\text{kN/m}^2$ (ULS)

Capacity of 75x50x8mm Angle:

Capacity of angle Based on 2400mmx1200mm Glass floor – (worst case):

Check 1 – 2400mm Long leg:

$f_y = 355\text{ MPa}$ (Grade S355 Mild Steel, Table 3.1 EN 1993-1-1:2005)

$E = 210,000\text{ MPa}$ (Grade S355 Mild Steel, Table 3.1 EN 1993-1-1:2005)

$I = 520000\text{ mm}^4$ (75x50x8mm Angle)

$Z = 10400\text{ mm}^3$ (75x50x8mm Angle)


$\gamma_Q = 1.5$ (Table 6.10 EN 1991-1-1:2002)

Maximum Moment = $\left(\frac{7.11\text{kN}}{\text{m}^2} \times 0.6\text{m} \times 2.4^2\text{m}\right) - \left(\frac{7.11\text{kN}}{\text{m}^2} \times 0.6\text{m} \times 1.2^2\text{m}\right) = 2.05\text{kNm}$

Maximum Stress:

$$\sigma_{\max} = \frac{M}{Z}$$

$$\sigma_{\max} = \frac{2.05 \times 10^6}{10400} = 198 \frac{\text{N}}{\text{mm}^2} < 355 \frac{\text{N}}{\text{mm}^2} \quad \text{Okay}$$



Maximum Deflection:


$$\alpha_{\max} = \frac{5w_e^4 l^4}{384EI}$$

$$\sigma = \left(1 - 1.6 \left(\frac{x}{L}\right)^2 + 0.64 \left(\frac{x}{L}\right)^4\right)$$

$$\sigma = \left(1 - 1.6 \left(\frac{0.6}{2.4}\right)^2 + 0.64 \left(\frac{0.6}{2.4}\right)^4\right) = 0.9025$$

$$w_e^4 = 0.9025 \times 4.825\text{kN/m}^2 \times 0.6\text{m} = 2.62\text{kN/m}$$

$$\alpha_{\max} = \frac{5 \times 2.62\text{N/mm} \times 2400^4\text{mm}}{384 \times 210000\text{N/mm}^2 \times 520000\text{mm}^4} = 10.4\text{mm} < 12\text{mm} \left(\frac{2400}{200}\right) \quad \text{Okay}$$



Therefore, use 75x50x8mm Grade S355 Mild Steel Angle.

Project: Angle Design	Contract: 1472-2
Subject: DESIGN D – 2400x1200mm	Sheet No. 5
Date: 19/10/2021	By: A.N

Check 2 – 1200mm Long leg:

$$f_y = 355 \text{ MPa} \quad (\text{Grade S355 Mild Steel, Table 3.1 EN 1993-1-1:2005})$$

$$E = 210,000 \text{ MPa} \quad (\text{Grade S355 Mild Steel, Table 3.1 EN 1993-1-1:2005})$$

$$I = 520000 \text{ mm}^4 \quad (75 \times 50 \times 8 \text{ mm Angle})$$

$$Z = 10400 \text{ mm}^3 \quad (75 \times 50 \times 8 \text{ mm Angle})$$


$$\gamma_Q = 1.5 \quad (\text{Table 6.10 EN 1991-1-1:2002})$$

$$\text{Maximum Moment} = \frac{7.11 \text{ kN}}{\text{m}^2} \times 0.6 \text{ m} \times 1.2^2 \text{ m} \times \frac{1}{12} = 0.512 \text{ kNm}$$

Maximum Stress:

$$\sigma_{\max} = \frac{M}{Z}$$

$$\sigma_{\max} = \frac{0.512 \times 10^6}{10400} = 50 \frac{\text{N}}{\text{mm}^2} < 355 \frac{\text{N}}{\text{mm}^2} \quad \text{Okay}$$



Maximum Deflection:

$$\alpha_{\max} = \frac{wl^4}{120EI}$$

$$w = 4.825 \text{ kN/m}^2 \times 0.6 \text{ m} = 2.895 \text{ kN/m}$$

$$\alpha_{\max} = \frac{2.895 \text{ N/mm} \times 1200^4 \text{ mm}}{120 \times 210000 \text{ N/mm}^2 \times 520000 \text{ mm}^4} = 0.46 \text{ mm} < 6 \text{ mm} \left(\frac{1200}{200} \right) \quad \text{Okay}$$

Therefore, use 75x50x8mm Grade S355 Mild Steel Angle.